

# Hierarchical Scheduling in an Intelligent Environmental Control System\*

TAG GON KIM

*Telecommunications and Information Sciences Laboratory, Department of Electrical and Computer Engineering, The University of Kansas, Lawrence, KS 66045, U.S.A.*

(Received: 26 December 1989)

**Abstract.** This paper describes the design and implementation of a hierarchical scheduling subsystem and graphical user interface in an intelligent environmental control system. The hierarchical scheduling system is capable of managing all environmental events occurring in widely different time scales as specified by the user. We employ a knowledge representation scheme called a system entity structure to specify the environmental schedules in a hierarchical fashion. A system entity structure called TAL (Timed Action Language) is developed. TAL organizes a family of all possible long-/mid-/short-term schedules from which a specific schedule can be pruned by the user through graphical interface.

**Key words.** Hierarchical scheduling, system entity structure, intelligent control.

## 1. Introduction

An intelligent environmental control system must be capable of managing environmental activities and conditions in an integrated fashion. Such activities range from planning of agricultural activities at the highest level to realtime control of environmental parameters at the lowest level. Activities at different levels give rise to hierarchical schedules which facilitate the timing of events to occur at different time scales. The design of such an intelligent control involves disciplines such as an artificial intelligence/expert system, automatic control, operations research, discrete-event system theory, and others [1, 2, 8, 9, 11].

This paper describes a hierarchical scheduling subsystem in such an intelligent environmental control system called AIDECS (AI-Based, Distributed Environmental Control System) which was developed at the University of Arizona as outlined in [4]. The AIDECS deals with control over environmental parameters such as temperature and humidity as well as scheduling crop planting and harvesting. The scheduling subsystem in the AIDECS supports specification of a hierarchical schedule, transforms it into a schedule object, and eventually maps it into rule-like activities which are continuously evaluated by an expert system-like evaluator.

The entity structure – a knowledge representation scheme using a labeled tree with attached variable types [12] – is employed to specify time-based schedules in a

\* Research was done while the author was a member of the Environmental Reseach Lab, University of Arizona. A Preliminary version of the paper was presented at 2nd International Conference on Industrial & Engineering Applications of AI and Expert System [5].

hierarchical fashion. The entity structure, originally used to represent the structure knowledge of a system with a family of variant models, can represent sub-components, decomposition, and taxonomic information about a system. In a hierarchical schedule specification, a system entity structure organizes a family of possible schedules from which a particular schedule can be selected by the user through the *pruning* operation. More specifically, our approach to hierarchical schedule specification is: (1) we define a system entity structure which organizes a family of all possible schedules called TAL (Timed Action Language), (2) the user specifies a schedule through the user interface system (either natural language interface or graphical interface), (3) a scheduling system prunes the TAL using information generated by the user interface, and (4) the pruned entity structure is the schedule specification. It is transformed into a set of rules for a real-time evaluator.

The paper is organized as follows. First it gives a short review of the system entity structure. It then presents the architecture of the AIDECS and briefly explains its subsystems. The paper presents details of the graphical user interface system and hierarchical scheduling subsystem written in Scheme [10] for execution on PC/ATs or TI Explorers. The conclusion of the paper outlines further work on the AIDECS, particularly on the schedule optimization subsystem.

## 2. The System Entity Structure

*System entity structure* (SES) is a representation scheme which contains the decomposition, coupling, and taxonomy information for a system [6, 12, 13]. Formally, SES is a labeled tree with attached variable types that satisfies five axioms – alternating mode, uniformity, strict hierarchy, valid brothers, and attached variables. A detailed description of the axioms is available in [12].

There are three types of nodes in SES – *entity*, *aspect*, and *specialization* – which represent three types of knowledge about systems. The *entity* node, having several *aspects* and/or *specializations*, corresponds to a model component that represents a real-world object. The *aspect* node (a single vertical line in the labeled tree of Figure 1) represents one *decomposition*, out of many possible, of an entity. Thus, the children of an aspect node are entities, distinct components of the decomposition. The *specialization* node (a double vertical arrows in the labeled tree of Figure 1) represents a way in which a *general* entity can be specialized into *special* entities.




Fig. 1. A system entity structure.

A *multiple entity* is an entity that represents a collection of homogeneous components. We call such components a *multiple decomposition* of the multiple entity. The aspect of such a multiple entity is called the *multiple aspect* (triple vertical lines in the labeled tree of Figure 1). Note that instead of presenting all BS components, only one B is placed in the labeled tree.

*Pruning* extracts a sub-structure of the SES by selecting one aspect and/or one specialization for each entity in the SES. The *pruning* operation also expands multiple entities as well as assigning values of attributes attached to entities in the SES.

SES has been realized in a Scheme environment. The realization called the ESP-scheme was described in [6]. The ESP-scheme is originally used as a means of representing structural knowledge for a simulation model in knowledge-based modeling/simulation research [3]. Here, we use the ESP-scheme as a tool for the specification of hierarchical schedules in the AIDECS.

### 3. System Architecture Overview

The AIDECS (Figure 2) consists of a consultation expert system (CES), user interface system (UIS), constraints checker (CC), schedule manager (SM), schedule executor (SE), schedule decision expert system (SDES), control data base (CDB), and a




Fig. 2. Overall system architecture.

real-time control and data acquisition system (RTCDAS). The CES contains the integrated pest management expert system (IPMES) and the diagnostic expert system (DES).

The UIS enables the user to specify a short-/mid-/long-term schedule for environmental activities and parameters in a hierarchical manner. The CC decides whether the schedule is acceptable or not by comparing it with a set of constraints contained within it, and sends it to the SM. The SM generates the specification of a hierarchical schedule, translates the specification into a schedule object, and sends the object to the SE. The SE transforms the object into a set of activities, each of which has slots for a condition/action pair, and others. The SE continually evaluates each activity in the set in conjunction with the SDES; if the condition of an activity is satisfied, the associated action in the activity is fired, which sends micro-level control signals to the RTCDAS. This signal has information on setpoints for environmental parameters such as temperature, humidity, and location where control actions are taking place. Data points that the RTCDAS collects by sensors are maintained in the CDB which the CES and the SDES might access as required.

The following sections provide details of graphical user interface subsystem and of the schedule generator within the SM subsystem. Description of rest of the components of the AIDECS can be found in [4, 7].

#### 4. Graphical User Interface

Two different types of user interfaces have been developed: natural language interface (NLI) and graphical interface (GI). There exists a one-to-one correspondence between information generated by the NLI and by the GI. The NLI facilitates specifying a time-based schedule with considerable freedom of expression. An augmented transition network is used to implement the syntax and semantics of schedule specification. The NLI, including its grammar, was reported in [4].

The GI is designed to facilitate specifying, showing, modifying, or executing a time-based schedule with a mouse. Developed in SCOOPS, an object-oriented programming superset of SCHEME, the GI employs a hypertext approach. The input of the GI is novel in that the user can draw curves graphically as well as enter texts via a keyboard for schedule specification as shown in Figure 3. The output information generated by the GI is used for automatic pruning of an entity structure representing a family of schedules.

Classes in the GI include a text menu class and a graphic menu class, each of which has its sub-classes. Instance variables and methods for these classes are provided to display, read, or select text menus, draw curves, and save specified information. More specifically, a method *when-receive-click* of the graphic menu class performs the following: (1) translates a current mouse position into a value of a control variable, and saves it in an instance variable, (2) displays the current position, and (3) draws a line from a previous position to the current one. Similarly, the method *when-receive-click* of the text menu class is to read a text for a keyboard, display it, and save in an instance variable.




Fig. 3. Graphical user interface.

The menu *specify* in Figure 3 displays questions about a schedule, one by one, to the user and text menus followed by graphic menus. Specifying text information for the schedule consists of answering by typing texts at mouse positions and/or selecting texts displayed on a screen using the mouse. Such information includes start-date, end-date, biome-type, plot-type, and others for the schedule.

Objects of the graphic menu class are used for specifying graphic information about the control of environmental variables such as temperature and humidity. Specifying such information involves graphically inputting curves which assign values of environmental variables and their associated time intervals. The schedule specified can be saved as required or discarded.

A daily schedule for temperature and humidity is shown in Figure 3. The natural language version of schedule specification is as follows.

From 1989/6/1 to 1991/5/31  
 for all PLOTS in IPM-GREENHOUSE Biome  
 for every 24 hours period  
 maintain temperature at 55 degrees for first 4 hrs  
   60 degrees for next 4 hrs  
   70 degrees for next 6 hrs  
   65 degrees for next 6 hrs  
   60 degrees for last 4 hrs  
 maintain humidity at 70% for first 12 hrs  
   75% for last 12 hrs.

The GI produces a set of variables with their values assigned as its output for the above input. Such a set of variables and their values, as shown in Figure 4, is used to generate entity structures for corresponding schedules. We shall explain details

```

start-date = 1989/6/1
end-date = 1991/5/31
biome-type = IPM-GREENHOUSE
plot-type = ALL
period = (24)
period-unit = (hrs)
control = ((maintain maintain maintain maintain maintain)
           (maintain maintain))
parameters = ((temperature temperature temperature temperature
              temperature) (humidity humidity))
parameter-values = ((55 60 70 65 60) (70 75))
parameter-units = ((deg deg deg deg deg) (% %))
duration-values = ((4 4 6 6 4) (12 12))
duration-units = ((hrs hrs hrs hrs hrs) (hrs hrs)).

```

Fig. 4. Output of graphical interface.

of such a schedule generation by automatic pruning processes in the following section.

The menu *show* shows schedules saved in a library called the schedule base. The schedule shown can be changed and executed as desired.

## 5. Scheduling System

### 5.1. SCHEDULE GENERATOR

The schedule generator (SG), a subsystem of the schedule manager, generates hierarchical schedules which facilitate the timing of events to occur at coarse- and fine-grained time and space units. An entity structure organizes a family of all possible schedules by its representation scheme; it can represent components, decompositions, and taxonomic knowledge of a schedule. The operation pruning defined on the entity structure allows the SG to generate a pruned entity structure representing a schedule specified by the user.

Using the ESP-scheme, we developed an entity structure called Timed Action Language (TAL) to organize a family of all possible schedules for the environmental control. As shown in Figure 5, entities, decompositions, and specializations with attached attributes in the TAL, represent all necessary information for the SG to generate user-specified schedules. For example, *entities* WHERE, START-DATE, END-DATE, CYCLE, and ACT&TIMS along with their attached attributes, designate region, start date, end date, period, and a sequence of control actions with associated time intervals, respectively. A *specialization* BIOME-SPEC specifies that a region (Biome) can be one of three types, namely, FOREST, SAVANNAH, or IPM-GREENHOUSE, each of which has its own plots with their own sectors. Such specialization allows the user to adjust the sensitivity of regions in which control actions are taking place for the specified duration.

Note that the TAL has a multiple entity ACT&TIMS whose child entity ACT&TIM specifies a control action with an associated time interval. Since the pruning operation on a multiple entity can generate an unlimited number of multiple children entities,




Fig. 5. Entity structure for timed action language (TAL).

the user can specify any sequences of control actions and their associated time intervals.

A schedule is specified in a hierarchical manner. Such a hierarchical schedule is represented by a set of pruned entity structures organized in a hierarchical fashion. An attribute *put-in-effect* attached to the entity ACTION is used to maintain an ordered list of entity structures for an entity structure, which represents the sub-schedules to be executed in a sequence of specified intervals. Each sub-schedule, in turn, recursively has its own sub-schedules. Such a capability allows the SG to generate hierarchical schedules on any level of hierarchy in time units. Putting into effect more than one schedule with the same interval, results in a joint schedule, a set of schedules, such as temperature and humidity schedules, being executed together.

Specification of a hierarchical schedule can take advantage of information inheritance; an entity structure transmits all information specified for a schedule, except cycle and action and associate timing, to its sub-entity structures. For example, a start date specified in an entity structure is inherited to all its sub-structures as default. However, a new start date, if specified in a sub-structure, can override the inherited one.

## 5.2. PRUNING: SCHEDULE SPECIFICATION

In a hierarchical structure, pruned entity structures with no sub-structures specify actual control actions, while those with sub-structures maintains a list of the sub-structures with their associated timing intervals. To explain how such actual control




Fig. 6. Pruned entity structure of TAL for schedule shown in Figure 3.

actions are specified by pruning the TAL, let us consider the schedule specified in Figure 3 of the GI. The figure shows a daily joint schedule to control both temperature and humidity.

The SG inputs information in Figure 4 and prunes the TAL. The SG generates two pruned entity structures for the temperature and humidity schedules, respectively. Let us call the pruned entity structures for the temperature control p:temp and for the humidity p:humid. To obtain the p:temp shown in Figure 6 involves the following procedures:

- assign values of attributes attached to the entities,
- select specialized entities under generalized ones,
- generate five ACT&TIMs for five control actions, and
- specify generated ACT&TIMs by assigning values of attributed and selecting entities under each such ACT&TIM entity.

More specifically, 1989/6/1 in Figure 4 is assigned as the value of the attribute date attached to the entity START-DATE for the p:temp. Similarly, the above values of end-date, period, and period-unit are assigned to values of the attribute date attached



to the entity END-DATE, and attributes the period and unit attached to the entity CYCLE, respectively. The values IPM-GREENHOUSE of the biome-type and ALL of the plot-type above are used to select entities IPM-GREENHOUSE and ALL-P for the p:temp under BIOME-SPEC and PLOTS-SPEC specializations in the TAL, respectively.

Length five of the first list in the values of variable control in Figure 4, is used to generate five ACT&TIMs for p:temp under the multiple entity ACT&TIMs. A list of values of the variable – control, parameters, parameter-values, parameter-units, duration-values, and duration-units – is used to specify the temperature and control actions for p:temp. Figure 6 shows all such assigned values of attributes but all entities including those under five ACT&TIMs. Similarly, the humidity entity structure, p:humi, can be obtained by using the values of the variables in Figure 4.

### 5.3. HIERARCHICAL SCHEDULE SPECIFICATION

We now show how a hierarchical schedule is specified by hierarchically constructing pruned entity structures, such as the p:temp and p:humi, of the TAL. Consider a hierarchical schedule shown in Figure 7.

- (1) For all plots in IPM-GREENHOUSE
- (2) from 1989/7/1 to 1991/6/31, perform the following schedule
- (3) for every year period
- (4)     for first 4 months
- (5)         for every month period
- (6)             for first 15 days
- (7)                 for every 1 day period
- (8)                     for first 8 hrs, maintain temperature at 50 degs
- (9)                     for next 8 hrs, maintain temperature at 60 degs
- (10)                    for last 8 hrs, maintain temperature at 70 degs
- (11)                 for last 15 days
- (12)                     for every 1 day period
- (13)                    for first 12 hrs, maintain temperature at 55 degs
- (14)                    for last 12 hrs, maintain temperature at 65 degs
- (15)     for next 4 months period perform a following joint schedule
- (16)         for every 1 day period
- (17)             for first 12 hrs, maintain temperature at 65 degs
- (18)             for last 12 hrs, maintain temperature at 75 degs
- (19)     for every 1 month period
- (20)         for first 10 days, maintain humidity at 70 %
- (21)         for next 10 days, maintain humidity at 75 %
- (22)         for last 10 days, maintain humidity at 80 %
- (23)     for last 4 months
- (24)         for first 2 months
- (25)             for every 10 days period
- (26)                 for first 5 days, maintain humidity at 70 %
- (27)                 for last 5 days, maintain humidity at 80 %
- (28)     for last 2 months
- (29)         for every 1 day period
- (30)             for first 10 hrs, maintain temperature at 70 degs
- (31)             for next 5 hrs, maintain temperature at 75 degs
- (32)             for last 9 hrs, maintain temperature at 80 degs.

Fig. 7. Hierarchical schedule specification.




Fig. 8. Pruned entity structure for Figure 7. Line numbers are those in Figure 7.

The schedule has a period of one year, for which three sub-schedules with their associated effective intervals are specified, each of which has its own sub-periods for which its sub-schedules are specified, and so on. Note that there are six actual control actions for temperature and/or humidity, which require six pruning processes. For example, lines (7)–(10) are presented by a pruned entity structure for the temperature control. We call the six pruned entity structures *p:temp1*, *p:temp2*, *p:temp3*, *p:humi1*, *p:humi2*, and *p:temp4*, accounting for lines (7)–(10), (12)–(14), (16)–(18), (19)–(22), (25)–(27), and (29)–(32), respectively. More specifically, the pruned entity structure *p:temp1* has three ACT&TIMs entities representing three temperature control actions with associated timings shown in lines (8), (9), and (10).

Lines (4), (15), and (23) indicate that the overall schedule has three sub-schedules, each of which lasts for four months. To specify the sub-schedules needs additional three pruned entity structures. We call such pruned entity structures *p:schedule1*, *p:schedule2*, and *p:schedule3* accounting for lines (4)–(14), (16)–(18), and (23)–(32), respectively. Another pruned entity structure, called *p:schedule* as a root, organizes the three sub-schedules. The pruned entity structure *p:schedule* has all information necessary for the schedule such as start date and end date specified in the line (2), area specified in the line (1), and others. Recall the inheritance property among hierarchically constructed pruned entity structures. *P:schedule* transmits such information to *p:schedule1*, *p:schedule2*, and *p:schedule3*, which transmit the information to their sub-entity structures listed above. Figure 8 shows the hierarchical structure of the pruned entity structures for the schedule of Figure 7. Note that *P:temp3* and *p:humi1* are in the same interval as a joint schedule, while others are in different intervals. The hierarchical structure of Figure 8 shows that a change of schedule can be made locally at any level of the temperature hierarchy.

## 6. Conclusions

We have described subsystems for hierarchical scheduling in the AIDECS under development. Particularly, the graphical user interface and schedule generator written

in Scheme have been discussed. The graphical user interface, developed in the object-oriented programming superset of SCHEME, allows the user to specify the schedule in a hierarchical fashion using hypertexts. The schedule generator generates hierarchical schedules by pruning the TAL with respect to user-specified information output by the graphical user interface. Within the AIDECS, hierarchical schedules have been tested on the real-time basis using two PC/ATs coupled to a computer network.

The development of a real-time decision-making system for schedule optimization is under consideration. The approach to schedule optimization for such an expert system is to combine rule-based expert system techniques for static (or long-term) optimization with modelling and simulation techniques for dynamic (or short-term) optimization. Details of the proposed approach have been outlined in [7].

## References

1. Hoshi, T. and Kozai, T.: Knowledge-based and hierarchically distributed online control system for greenhouse management, *Acta Horticulture* **148**, 301-303 (1984).
2. Jacobson, B.K., Jones, J.W., and Jones, P.: Tomato greenhouse environment controller: real-time expert system supervisor, ASAE Technical Paper No. 87-5022 (1987).
3. Kim, Tag Gon: A knowledge-based environment for hierarchical modelling and simulation, Doctoral dissertation, Electrical and Computer Engineering Dept., University of Arizona, Tucson, AZ (1988).
4. Kim, Tag Gon, Mignon, G., and Zeigler, B.P.: Design of an AI-based self-sustaining habitats control system, *Proc. First Internat. Conference on Industrial & Engineering Applications of Artificial Intelligence & Expert Systems*, Tullahoma, Tennessee (1988), pp. 1059-1065.
5. Kim, Tag Gon and Zeigler, B.P.: Hierarchical scheduling in an intelligent environmental control system, *Proc. Second International Conference on Industrial & Engineering Applications of Artificial Intelligence & Expert Systems*, Tullahoma, Tennessee (1989).
6. Kim, Tag Gon and Zeigler, B.P.: ESP-scheme: a realization of system entity structure in a LISP environment, *Proc. AI and Simulation of 1989 SCS Eastern Multiconference*, Tampa, Florida (1989).
7. Kim, Tag Gon: Design of intelligent control system: vol. 1, Tech. Report, ER Lab., University of Arizona (1988).
8. Saridis, George N.: Knowledge implementation: structures of intelligent control systems, *Proc. IEEE International Symposium on Intelligent Control*, Philadelphia, PA (1987).
9. Schapendonk, A.H.C.M., Challa, H., Broekharst, P.W., and Udink ten Cate, A.J.: Dynamic climate control: an optimization study for earliness of cucumber production, *Scientia Horticulturae* **23**, 137-150 (1984).
10. *TI Scheme Language Reference Manual*, Texas Instruments, Dallas, TX (1985).
11. Udink ten Cate, A.J. & Challa, H.: On optimal computer control of the crop growth system, *Acta Horticulture* **148**, 267-276.
12. Zeigler, B.P.: *Multifaceted Modelling and Discrete Event Simulation*, Academic Press, New York (1984).
13. Zeigler, B.P.: Knowledge representation from Minsky to Newton and beyond, *Applied Artificial Intelligence*, vol. 1, Hemisphere Pub., Co. (1987), pp. 87-107.